AMX Intergration



AMX INTEGRATION OVERVIEW:

Take your motorized window treatment experience to the next level by integrating them into your AMX smart home control system. The integration supports isolated shade control and features a two-way communication system offering real time shade position.

The Wi-Fi Bridge is available for purchase through Rollease Acmeda. It can integrate up to 30 shades and supports plug in play RS485 Serial integration through a RJ9 port conveniently located on the back of the Bridge

GETTING STARTED:

In order to integrate your motorized window treatments with AMX, you will need to have:

- Downloaded the free app via the Apple App Store (available under iPhone apps) or the Google Play Store.
- Purchased one or more Wi-Fi Bridges depending on size of the space.
- Integrated your motorized window treatments onto the Rollease Acmeda app

INSTRUCTIONS INCLUDED

- Set up instructions for both the Rollease Acmeda app & Wi-Fi Bridge
- AMX Driver Installation Instructions
- AMX Driver Guide
- Integration Diagram
- Integration FAQ's
- Integration FAQ's







AMX Intergration

ABOUT THE APP:

Rollease Acmeda app allows for control of your motorized window treatments through your smartphone/ tablet.

The App allows for:

- Individual and group control
- Scene control
- Timer functionality

INSTRUCTIONS INCLUDED

In order to control your motorized window treatments through the Rollease Acmeda app, you will need to have:

- Downloaded the free app via the Apple App Store (available under iPhone apps) or the Google Play Store.
- Purchased one or more Wi-Fi Bridges depending on size of the space.



WI-FI BRIDGE TECHNICAL SPECIFICATIONS:

- Radio Frequency range: ~60 feet (no obstructions)
- Radio Frequency: 433 MHz
- Wi-Fi: 2.4 GHz
- Power: 120V AC
- For Indoor Use Only

SETUP BEST PRACTICES:

- Bridge must be within signal range of both the motorized window treatments and the Wi-Fi router.
- Wi-Fi network must be visible.
- Environments with multiple WAPs (wireless access points) may need to temporarily disable all but one.
- Security settings may need to be temporarily disabled.

CAPABILITIES:

•

•

- Motors per Bridge: 30
- Locations per account: 5
- Wi-Fi Bridges per location: 5
- Rooms per Location: 20
- Scenes per Location: 20
- Timers per Location: 20





WHAT'S INCLUDED:

- 1 x Rollease Acmeda Wi-Fi Bridge
- 1 x 6" Short Power Cord
- 1 x 12" Long Power Cord
- 1 x Outlet Power Plug
- 2 x Antiskid Pads

UNPACKING THE WI-FI BRIDGE:



1.UNPACK THE WI-FI BRIDGE.



2. INSERT USB END OF THE POWER CORD (LONG OR SHORT) INTO THE OUTLET POWER PLUG.



3.INSERT THE MICRO USB END OF THE POWER CORD (LONG OR SHORT) INTO THE WI-FI BRIDGE.



4.PLACE THE BRIDGE IN A CENTRALLY LOCATED POSITION IN YOUR HOME AND PLUG IN TO OUTLET. (YOU MAY NEED TO EXPERIMENT WITH DIFFERENT LOCATIONS TO BE ABLE TO REACH THE DESIRED SHADES).







SETTING UP THE APP:



Open The Automate Pulse mobile application.



If required, create a new account. Select Sign Up on the bottom left corner of the screen.



Creating an account will require an email address and a password.

STEP 4



SIGN IN with your account information.



Link the application to the new Wi-Fi Bridge. Select the menu button in the upper left corner of the home screen (3 lines).



Select the default "Home" option under LOCATION to open Location Settings.

	0	
II AT&T LTE	12:39 PM	\$ 63% 🔳
K Back	LOCATION SETTINGS	Done
NAME		My House 🗲
PICTURE		
HUBS		
Demo		>
ADD NEW HU	JB	
	DELETE LOCATION	
	\bigcirc	

Select "ADD NEW HUB" to enter the pairing process.






PAIRING THE APP & WI-FI BRIDGE

STEP 9



Follow on screen instructions to pair the new Wi-Fi Bridge to the application Ensure Wi-Fi Bridge is plugged in. Select "Next".

STEP 13



Name your Wi-Fi Bridge to complete the Wi-Fi connection process.



All of the shades and scenes configured in your Automate Pulse app will now appear in the Devices section of the Alexa app.



Hold the Wi-Fi Bridge set button for 2 seconds. The bridge will start blinking blue to signify it is ready to pair to the network.



The Wi-Fi Bridge will attempt to pair to your Wi-Fi network for 60 seconds. Select "Set Hub" after success.





PAIRING TROUBLESHOOTING:

STEP 14




There are a number of factors that will influence the network pairing process. Some networks require more time to make the initial communication links with the application servers.

In the event you receive the "Connection Failed" screen, we suggest you reattempt the pairing sequence by selecting "Auto Configuration". This will redirect you to complete the above process again. If then unsuccessful again you may choose the second connection path by selecting "Manual Configuration". See Manual Configuration steps below.

There are a number of factors that will influence the network pairing process. Some networks require more time to make the initial communication links with the application servers.

MANUAL CONFIGURATION



Select the XPG-GAgent-XXXX network and

enter the default password 123456789.

Return to the Automate Pulse app.


Using a paper cup, press and note the recessed button on the Wi-Fi Bridge until the Bridge blinks blue 3 times. Press next when the Bridge begins blinking red.

rolleaseacmeda.com © 2017 Rollease Acmeda Group




the password for your Wi-Fi


network. Enter your Wi-Fi







MANUAL CONFIGURATION



In the event that after the manual config process completes you are directed to the Connection Failed screen again. Confirm your Bridge



This will allow you to manually connect the Wi-Fi Bridge to your App. Press "Scan QR Code" You must allow The Automate Pulse app rights to use your smartphone/ tablet camera when prompted.




On the bottom of your Wi-Fi Bridge there will either be a Number/ Letter code or a small QR code. Use the camera to scan the QR code or manually type in the Number/Letter code and press OK.

-	0	
HUB NAME >>	🕻 Back	Done
MAC ADDRESS ACCF23CF0000	HUB SETTINGS	
	HUB NAME	>
LOCATION Hub Updates	MAC ADDRESS	ACCF23CF0000
	LOCATION	Hub Updates

STFP 22

On the settings screen you will be prompted to name your Wi-Fi Bridge. Name your Bridge and press OK to complete the Wi-Fi connection process.

HOW TO LINK EACH SHADE TO THE APP:



and select "Next".







rolleaseacmeda.com © 2017 Rollease Acmeda Group

device.

HOW TO LINK FACH SHADE TO THE APP:






PAIRING COMPLETE

Once the motors have paired, the application will take you directly to the shade properties screen to edit the settings for your treatment.

HOW TO EDIT SETTING FOR EACH SHADE:







SETTING & SCENE INSTRUCTIONS

0 <u> </u>	
ANALATE 1239 PM 6 5% C	1
ROOMS DEVICES	
(+)	
None President Scenes Timers	1

CTED 22



	0 —	
I AT&T 🌩	11:22 AM	* 31% -
< Back	Boardroom	Edit
Open All	Close All	50%
+		
L	\bigcirc	
	\bigcirc	

shade to the room.

Select "Add Existing Device" to select select the "Plus" icon to add a linked treatments from the dropdown to add to the room. (Choosing "Add New Device" will revert back to the pairing a

new device sequence.)

STEP 35

0 —

ADD NEW DEVICE ADD EXISTING DEVICE Cancel

Once all shades are linked to the application. Click "ROOMS" tab. Select the "Plus" icon to add a new room designation, return to the home screen, Select "Room"

Name the room, pick the room icon and click "Done"

SET-UP COMPLETE

Your mobile application setup and product pairing is now complete. Shades added to rooms can be controlled simultaneously after selecting the desired room. See the following sections for instructions on creating scenes, setting timers and troubleshooting pairing failures.

Once you have completed the pairing process for the Wi-Fi bridge and linked all of your shades to the application, you can create scenes to set a covering or group of coverings to specific heights.

1. On the lower menu bar select the Scene icon. This will take you to the scene homepage.

2. Select "Add New Scene" to begin programming your desired scene. 3. Input your scene name and select a scene picture.


4. You can choose custom heights (by %) or set open/closed for all selected coverings. (If you select custom you must select a covering height for each selected treatment)

5. Select "Add New Device" to add your covering to the scene being created

6. Set the covering height percentage if necessary.

7. Select "Done" to finalize your scene.

You can activate your custom scene by navigating to the scene menu, and pressing "GO" next to the desired scene name. If you wish to set a programmed timer to activate your scene or individual shades, please see the next section "Programming Timers".










CREATING SCENES:

Once you have completed the pairing process for the Wi-Fi bridge and linked all of your shades to the application, you can create scenes to set a treatment or group of treatments to specific heights.


- **1.** On the lower menu bar select the Scene icon. This will take you to the scene homepage.
- 2. Select "Add New Scene" to begin programming your desired scene.
- 3. Input your scene name and select a scene picture.
- 4. You can choose custom heights (by %) or set open/closed for
- all selected treatments. (If you select custom you must select a
- treatment height for each selected treatment)
- ${\bf 5.} \mbox{ Select "Add}\ \mbox{New Device" to add your treatment to the scene being created. }$
- 6. Set the treatment height percentage if necessary.
- 7. Select "Done" to finalize your scene.

You can activate your custom scene by navigating to the scene menu, and pressing "GO" next to the desired scene name. If you wish to set a programmed timer to activate your scene or individual shades, please see the next section "Programming Timers".



	10:56 AM	* 34%
< Back	ADD NEW SCENE	Don
SCENE SETTINOS		
SCENE NAME		Morning
SCENE PICTUR	E	
DEVICE SETTINOS		
CUSTOM	OPEN ALL	CLOSE ALL

PROGRAMMING TIMERS



You can program timers to trigger the specific operation of your shades and scenes at your desired times throughout the day.

1. On the lower menu bar select the Timer icon. This will take you to the Timer homepage.

- 2. Select "Add New Timer" to begin programming your desired timer.
- 3. Select either "Add Device Timer" or "Add Scene Timer"
- 4. Input your timer name and select a timer picture.
- **5**. Add the devices or scenes you wish to operate.
- 6. Set the time you wish the timer to trigger shade control.
- 7. Select the days you wish the timer to operate. (Black dot signifies the timer will repeat on that day)
- 8. Select "Done" to finalize your timer.

You can turn your timer on or off to accommodate changes to your regular schedule. Slide the on/off selector on the Timer homepage next to the desired timer to activate or deactivate the time based control.





LED INDICATION

COLOR	RESPONSE	STATUS
	Flashes Twice	Power On
-0-	Continuous Flashing	Wi-Fi Bridge is in pairing mode
	Flashes Three Times	Wi-Fi Bridge has been reset for manual configuration
0	ON	App is connected to Wi-Fi Bridge
0	Continuous Flashing Blue to Purple	Wi-Fi Bridge is connected to Wi-Fi router (no cloud connection)
-Ò.	1 Flash Every 5 Seconds	Wi-Fi Bridge is connected to cloud server and is in stand-by mode
-Ò.	Continuous Flashing	Wi-Fi Bridge is not connected to Wi-Fi and is actively searching for a Wi-Fi signal
-Ò	Flashing	Wi-Fi Bridge's firmware is being updated

TROUBLESHOOTING:

The following scenarios are common issues that may cause connectivity problems during the Wi-Fi bridge pairing process. If you cannot achieve success connecting the Wi-Fi Bridge to your network, please reference the below most common pairing roadblocks.

I CANNOT CONNECT TO MY HIDDEN WI-FI NETWORK.

Rollease Acmeda Wi-Fi Bridge does not currently support pairing with hidden networks. To connect to a hidden network, you will need to unhide the network. Once the network pairing process is complete you can re-hide the network and the Wi-Fi Bridge will work without issue.

I HAVE MULTIPLE ACCESS POINTS AND CANNOT COMPLETE THE PAIRING PROCESS.

If you have multiple wireless access points we recommend that you turn off all but one to complete the network pairing process. Once this is complete you can turn on all of the wireless access points and the Wi-Fi Bridge will work without issue.

I CANNOT CONNECT TO MY 5GHZ WI-FI NETWORK.

Rollease Acmeda Wi-Fi Bridge does not currently support operation over a 5GHz network. It operates on a 2.4GHz network. Most routers are dual band and can support both network configurations. Please make sure that the 2.4GHz band is turned on in your wireless router's settings.

NETWORK SECURITY SETTINGS ARE INTERFERING WITH THE SETUP PROCESS.

Some companies or large corporate offices have network security settings more advanced than the typical homeowner. If you are setting up in this environment please consult your network administrator. It may be necessary to enable device-to-device communication. One solution is to use a device with a mobile data connection available in the background to complete the set-up process.

MY WI-FI BRIDGE IS NOT CONSISTENTLY WORKING.

There are many things that can interfere with the radio communication that the Wi-Fi Bridge uses. Try positioning the Wi-Fi Bridge in a different location and/or closer to the shade to improve performance. Due to varying levels of interference it may be necessary to purchase additional Wi-Fi bridges to extend the coverage throughout your location.

For further assistance, contact your retailer, visit our website at www.rolleaseacmeda.com or email us at; automate@rolleaseacmeda.com





1. Find Rollease ARC Example file- downloadable at AMX third party tech center. Open with Netlinx.

Name	Date modified	Туре	Size
Packaged	12/21/2017 9:05 AM	File folder	
gitignore	12/21/2017 9:02 AM	GITIGNORE File	1 KB
💼 Duet Rollease Acmeda ARC Interface.doc	1/4/2018 4:23 PM	Microsoft Word 9	175 KB
at MotorComponent.axs	12/20/2017 6:52 PM	NetLinx Studio 4 A	9 KB
MotorComponent.src	1/15/2018 1:25 PM	SRC File	28 KB
MotorComponent.tkn	1/15/2018 1:25 PM	TKN File	103 KB
MotorComponent.tko	1/15/2018 1:25 PM	TKO File	534 KB
NS Rollease Acmeda ARC Example.apw	12/15/2017 2:51 PM	NetLinx Studio 4 A	5 KB
AXX Rollease Acmeda ARG Example.axsPW File	1/15/2018 2:48 PM	NetLinx Studio 4 A	7 KB
Rollease Acmeda ARC Example.src	1/15/2018 1:26 PM	SRC File	31 KB
Rollease Acmeda ARC Example.tkn	1/15/2018 1:26 PM	TKN File	1,856 KB
Rollease Acmeda ARC Example.tko	1/15/2018 1:26 PM	TKO File	532 KB
TP4 Rollease Acmeda Netlinx Demo.TP4	1/15/2018 2:19 PM	TP4.Document	2,059 KB

2. Click Tools. Select File Transfer.

that they should like its provide them						
A REAL PROPERTY OF	and the second se	-				
The second s	Control Designs					
Hope Deeps Start Augenbase Claim St	in 👔 Californi Bangle,					
	The second second	and the second				
	The later					
	S many parameters.	The second second				
		A STORE STORE				
	Classification and the second	and the state of the set				
		- State of the second stat	A DECISION OF A DECISIONO OF A			
	By the Bulletine					
	The structure states	antes are entre	a data hay an and			
	The second second	State Links Longers	Barbar Jaco Pala Artesta			
	Contra Chat and Natio	and the second second	in particular in the second statistic on an approximation			
	The second ration	COLUMN TRACTORY	And and the second s			
	The second second	a de la sector de la de la d				
	N	a size facilitation formation	a for last descent			
	State State State					
	P Concept Date of Concepts	States and second second second	and the second se			
	Transaction and the	CONTRACT OF STREET, STREET, ST.	the second s			
	and and a second se		Contractions, which we are static to static tax of			
	100					
	24					
	200.00	4				
	200 C	CONTRACTOR OF A				
	and the second se	The local distance in the second	and these linearies and the			
	100	The Property Sector Process				
	and the second sec	and the second	A COMPANY AND A COMPANY			
	100					
	100	a province of the				
	100	A COLUMN ADDRESS OF				
	10 M					
		Colore contractor	hand to be			
		And the second s				
		state protocol and successive	ner (* 1936 - Albeitenskeheleners, 1, 8, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1,			
		-				
	the second s					
	20 10 20	a second second second				
	20	Contraction of the local distance	NAME OF TAXABLE AND ADDRESS OF TAXABLE ADDRESS OF T			
	and the second se					
	100	and the second data was in the	the second			
	Management of the local division of the loca	Contrast Contrast Contrast Contrast				
	THE OWNER OF THE OWNER					
		and second	manual and had		take and internet	
		Street, N. Street,	Contraction of the second seco	In the second seco	the many family is been and	
	A heat meaning	NUMBER OF STREET	and and any other to any services	In the local distance of the state of the state of the state	And Makes Advanced to the second	
	 A factor transformer A factor transformer 	The second second	the second site with a second based on the second sec	2. Annual Matter Control Co	Los house from a los house	
		Sector in case	(a) and (b) and (b) is a first defined party (b) party (c) party (c) and (c	to first the first interest when the second state	the states, charge is, but himself	
		Tank of Long.	and and any other states and and the second states and the second states and	 Sector Made a Sector Active and Sector Sectors Sector Science Science Sectors 	- Dis Salar Angel & Bir Line P	
ange lans						
na jar						
	- A new constants	No. of Concession, Name of Street, or other	. Jonana Havan I			







3. File Transfer window will open. (Assuming connection settings are established and functional.) Select "Rollease Acmeda ARC Example" file to send to control system. Click SEND.

citements all'informational				- 7 7 7
and Bull Depunds Drive Bull billing Weslam May				
「白」「「「白」「白」「白」「白」「白」「白」「白」「白」「白」「白」「白」「白				
a an interview of the second secon				
Deep Radiothour Club for Instant 11 CMM Recolutioner11				
The product starting				
1				
The 1+ LUCKEND DEFINITIONS OF BELOW +1				
RV				
at general contract				
11 1* Provided Advantation advancements on Press *1				
H -OFFICE WYTCHLD, DOCUMPAT				
II I NEWTON PROTOCOL APPROPRIATION OF A DATA				
R				
H PERMIT STATE FOR ALL ALL ALL ALL ALL ALL ALL ALL ALL AL				
15 (* BARNAR) URBER (MARKET (TRANSPORTED) *) 15.				
H (************************************				
a and a second se		×		
		10.00		
and the state of t				
100 Internet and the second ready room out to a manufacture.		N		
100 Charles and an a	and Advantance Report Palace Area Report	C.David Holds, Jackner Dourse (AUR-K)		
201 DEFERSION ACCOUNT Vietnet Commented Commentations				
The second				
104 DEEDE MODULE Michael Approximation and According to Compare and Compare				
107 -00708_00204 (AntonConstant) weblenets of				
118. 000710. 0000				
110				
111 -CANNEL_PROF Indefallence, MeinleConnels				
115 m				
and the second s				
111 Of Informations, County, County, 1	and the second s			
117 MPT	and the second by the second s	Zhen 1 h		
121 OF Lieferschleteri, COURT, COURT,				
and international generation	pairs. Spin. 1-Reserve and and	rahmai (balannan.		
181				
LII -040,0001 (cherciteral)				
441 1				
115. 0 /00.000				
127 Independenting, 2011 - Indefendent, 2011				
A REAL PROPERTY AND A REAL				
dEntersCorporation Elizaber tormit the Constitute				
najaris.				
Say free Bree Senthurd Commin B		les à	Rece Der Derrite	
2 See concerns access in carrier. An array carrier in an array of the concerns and the concerns and the concerns and the array of the concerns and the concerns and the concerns and the array of the concerns and the concerns and the concerns and the array of the concerns and the concerns and the concerns and the array of the concerns and the concerns and the concerns and the array of the concerns and the concerns and the concerns and the array of the concerns and the concerns and the concerns and the array of the concerns and the concerns and the concerns and the array of the concerns and the conce	In the second	5. Control of the state of t	New Hostory, Assessing 26, 2021 13 of 47	
Zana samanta an	NAMES AND ADDRESS OF TAXABLE PROPERTY.	Contraction of the second	NUM MINER, AMART AL AND ATACT	
Vani Augusta 19710-2 22011 20 50 50 50 51 51 5	المز الركر الترسط والعداق والعداق والعاد الت	P. One of MPRPs Physical Intel Completion Propility	Nam. Booksy, Assess p. 76, 1013 18 of 47	
Zana samana sana na sana ang ang ang ang ang ang ang ang ang		CONTRACTOR DESIGNATION OF THE OWNER.	NOT MORE ADDRESS AS AND APPRICE	
Charl Anglein 1944 of 1946 197 198 197 198 197 198	h Tana kanda MP Enegle en-	2. One of the off is the function of the state of the function of the state.	Box Boolog, Asses p. 76, 7013 13 all 47	
- and				
Teach				

- 4. Interface will present on touchpanel.
- 5. Click "Command Processor" button. Button will illuminate orange.

O ROLLEASE	COMMAND PROCE	ESSOR	INITIALIZ COMMUNICATI	
HUB ADDRESS	SETUP			
MOTOR ADDRESS				
PROCESSOR CONTROL 1	MOTOR MOTOR CONTROL 3	MOTOR CONTROL 4	MOTOR CONTROL 5	HOME





6. Click "Setup". Button will illuminate orange.

O ROLLEASE	COMMAND PROCESSOR	INITIALIZED COMMUNICATING	0
HUB ADDRESS	SETUP		
MOTOR ADDRESS			
COMMAND PROCESSOR CONTROL 1	MOTOR MOTOR CONTROL 2 CONTROL 3 CONTROL 4		OME

7. Using a remote or the Rollease Acmeda App, move each shade to initiate a response (in order to identify address).

8. Hub and motor addresses will automatically populate. Jog each motor in RA app to identify address.

C ROLLEASE	СОММА	ND PROC	ESSOR	INTH COMMUNIC	ALIZED ATING	00
HUB ADDRESS		SEILP				
		719				
MOTOR ADDRESS		002				
CCMMAND MOTOR PROCESSOR CONTROL 1	MOTOR CONTROL 2	MOTOR CONTROL 3	MOTOR CONTROL 4	MOTOR CONTROL 5	HOME	

rolleaseacmeda.com © 2017 Rollease Acmeda Group




AUTOMATE

9. Once you have identified each shade, configure the RA module for each hub/motor in Netlinx. Refer/ to "Duet Rollease Acmeda ARC Interface" document located in the zip file in the Duet module for advanced system configuration.

148	111111111111111111111111111111111111111
149	// Configure Rollease Acmeda Virtual Devices
150	
151	SEND COMMAND vdvRollease, "'COMPONENTADD-', ITOA (vdvMotorl.PORT), ', MOTOR[001]'"
152	SEND COMMAND vdvRollease, "'COMPONENTADD-', ITOA (vdvMotor2.PORT), ', MOTOR[002]'"
153	SEND COMMAND vdvRollease, "'COMPONENTADD-', ITOA (vdvMotor3.PORT), ', MOTOR[003]'"
154	SEND COMMAND vdvRollease, "'COMPONENTADD-', ITOA (vdvMotor4.PORT), ', MOTOR[004]'"
155	SEND COMMAND vdvRollease, "'COMPONENTADD-', ITOA (vdvMotor5.PORT), ', MOTOR[005]'"
156	

INTEGRATION DIAGRAM

WI-FI BRIDGE CONNECTIONS:



FREQUENTLY ASKED QUESTIONS:

NO WI-FI BRIDGE (AUTOMATE PULSE HUB) DETECTED.

Make sure that the correct 485 port is defined on the AMX controller.

SHADE LIMITS ARE NOT SET PROPERLY

Calibrate shade limits with your remote control before configuring shade in AMX system.

SHADE IS NOT MOVING AT ALL

Make sure the selected Wi-Fi Bridge (Automate Pulse Hub) is the correct Wi-Fi Bridge (Automate Pulse Hub) for the shade to be controlled.

I HAVE MULTIPLE WI-FI BRIDGES (AUTOMATE PULSE HUBS), WHAT DO I DO?

Multiple Hubs are automatically detected during discovery.

HOW DO I SCAN FOR AVAILABLE HUBS?

Utilize the Touchpanel to scan motors/hubs as they are moved from the Rollease Acmeda app or remote control.

SUPPORT RESOURCES:

For further assistance, contact your retailer, visit our website at www.rolleaseacmeda.com or email us at; automate@rolleaseacmeda.com



